



GUIDE SPECIFICATION

TYPE: LINEA ACCENT WOOD BEAM

PROJECT:

09 54 00 – ACCENT WOOD BEAMS

PART 1–GENERAL

1.1 SUMMARY

A. Section Includes:

1. Accent Wood Beams.
2. Accessories

1.2 RELATED WORK IN OTHER SECTIONS:

- A. Division 1 – “General Conditions” for substitution requests, submittals, etc.
- B. Division 9 – “Acoustic Ceilings.”
- C. Division 13 – “Integrated Assemblies.”
- D. Division 15 – “Mechanical” for work to be coordinated with ceiling.
- E. Division 16 – “Electrical” for light fixture coordination.

1.3 REFERENCES

- 2 .1 ASTM International (ASTM):
- 3 .1 ASTM A641/A641M–19—Standard Specification for Zinc Coated (Galvanized) Carbon Steel Wire.
- 4 .2 ASTM C423–22—Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method.
- 5 .3 ASTM C635/C635M–22—Standard Specifications for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-In Panel Ceilings.
- 6 .4 ASTM C 636/C636M–19—Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels.
- 7 .5 ASTM E84–21a—Standard Test Method for Surface Burning Characteristics of Building Materials.
- 8 .6 ASTM E 580/E580M–22—Standard Practice for Application of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions.
- 9 .7 ASTM E 1264-22—Standard Classification of Acoustic Ceiling Products.
- 10 .2 Architectural Woodwork Manufacturers Association of Canada (AWMAC):
- 11 .1 AWI/AWMAC—Architectural Woodwork Quality Standards Illustrated, current edition.
- 12 .3 Ceiling and Interiors Systems Construction Association (CISCA):
- 13 .1 CISCA—Ceiling Systems Handbook, current edition.
- 14 .4 National Building Code of Canada, Alberta edition 2019.

14.1 QUALITY ASSURANCE

- A. **Manufacturer Qualifications:** Manufacturers other than those listed in Paragraph 2.1 are required to submit for approval prior to bidding per Section One.
- B. **Installer Qualifications:** Engage an experienced Installer, approved by wood ceiling manufacturer, who has completed panel ceilings similar in species, design, and extent to that indicated for this Project and with a record of successful in-service performance.
- C. **Inspection:** All work must pass inspection and approval of architect, as well as the local codes and regulations or authorities having jurisdiction.
- D. **Single-Source Responsibility for Wood Ceiling System:** Obtain each type of Linear Wood Ceiling Panels from a single fabricator, with in-house Shop Drawing capabilities, in-house assembly and finishing capabilities, and with resources to provide products of consistent quality in appearance and physical properties without delaying the project.
- E. **Single-Source Responsibility for Suspension System:** Obtain each type of suspension system from a single source with resources to provide products of consistent quality in appearance and physical properties without delaying project.
- F. **Pre-Installation Conference:** Conduct conference at Project site to comply with requirements of Division 1 Section "Project Meetings."

14.2 SUBMITTALS

- A. **General:** Submit each item in this Section according to the Conditions of the Contract and Division 1 Specification Sections.
- B. **Product Data:** For each type of product specified.
- C. **Samples:** For verification of each type of exposed finish required, prepared on samples of size indicated below. Where finishes involve normal color and texture variations, include sample sets showing the range of variations expected.
 - 1. 12" Long samples of each panel type, pattern, and color.

14.3 SHOP DRAWINGS & COORDINATION WITH OTHER TRADES

- A. **Shop Drawings:**
Provide Shop Drawings/Coordination Drawings for all ceilings, which should include RCP and product details. Coordinate Accent Wood Beam layout, installation and suspension system components with other construction elements that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system components, partition assemblies and all perimeter conditions.

14.4 PROJECT CONDITIONS

- A. **Space Enclosure and Environmental Limitations:**
Do not install Accent Wood Beams until spaces are enclosed and weatherproof, wet-work in spaces is completed and dry, work above ceilings is complete, and ambient temperature and humidity conditions are being maintained at the levels indicated for Project when occupied for its intended use.

14.5 DELIVERY, STORAGE, AND HANDLING

- A. **Delivery & Unloading:** Coordinate crate sizes, weights, unloading options, and delivery schedule with manufacturer prior to fabrication. Deliver Accent Wood Beams and suspension system components to Project site in original, unopened packages and store them in a fully enclosed space where they will be protected against damage from moisture, direct sunlight, surface contamination, and other mistreatment.
- B. **Acclimatization:** Before installing Accent Wood Beams, permit them to reach room temperature and a stabilized moisture content (at least 72 hours) per AWI standards.
- C. **Handling:** Handle Accent Wood Beams carefully to avoid chipping edges or damaging units in any way.
- D. **Protection:**
 - 1. **Personnel:** good safety and industrial hygiene practices during handling and installing of all products and systems, with personnel to take necessary precautions and wear appropriate protective equipment as needed. Read related literature for important information on products before installation. Contractor to be solely responsible for all personal safety issues during and subsequent to installation; architect, specifier, owner, and manufacturer will rely on contractor's performance in such regard.
 - 2. **Existing completed work:** Protect completed work above suspension system from damage during installation of suspension system components.

14.6 EXTRA MATERIAL/WARRANTIES

- A. **Extra Materials:** Furnish extra materials described below that match products installed, are packaged with protective covering for storage, and are identified with labels clearly describing contents.
1. **Accent Wood Beams:** Furnish quantity of full-size units equal to 2.0 percent of amount installed.
 2. **Suspension System Components:** Furnish quantity of each component equal to 2.0 percent of amount installed.
- B. **Warranties:** Provide owner with a (1) year warranty for material and workmanship on all installed products.
1. **Manufacturers:** All materials, Accent Wood Beams, and suspension systems, shall be warranted for (1) one year for material and workmanship.
 2. **Installer:** All work shall be warranted for one (1) year from final acceptance of completed work

PART 2—PRODUCTS

2.1 LINEAR WOOD PANELS AND SUSPENSION SYSTEM

- A. **General:** The following manufacturer is basis of design:
1. LINEA Ceiling & Wall Systems
2320 Peardonville Road, Abbotsford, BC, Canada, V2T 6J8
Ph. 1-604-776-2265 | **Website:** lineaceilings.com | **Email:** sales@lineaceilings.com
- B. Or equal, as prior approved by architect.
- C. **Substitution:** Not permitted

2.2 LINEA ACCENT WOOD BEAMS

A. Basis of Design: LINEA ACCENT WOOD BEAM

1. LINEA Ceiling & Wall Systems. (lineaceilings.com)

1. **Veneer:**
2. **Core:** Class A Fire Rated
3. **Edge Banding:** To match veneer species and finish.
4. **Beam Width:** 6"
5. **Beam Depth:** 6"
6. **Beam Length:** 96"
7. **Radius:** None
8. **Style:** Non-Perforated
9. **Face Texture:** Smooth
10. **Color:** Natural
11. **Finish:** Clear
12. **Fire Rating:** Class A

2.3 SUSPENSION SYSTEMS, GENERAL

- A. Attachment System for Wood Beams shall be suspended according to manufacturers suggested method of suspension as per the design details provided in the plans.
- B. Fabricate Wood Beams to attach to the ceiling/floor deck above. Beams may be suspended using threaded eyelets and hanger wire, threaded rod or strut channel with slots, appropriate uniform load rating for beam configuration and spacing. Wood Beams are intended for decorative purposes only, electrical fixtures, HVAC equipment and fire suppression components should be independently supported and shall not rest on or wrap around the beams in any way.
- C. **Metal T–Grid Suspension System:**
Provide standard interior Metal Heavy Duty 15/16” suspension T–Grid system using Main Runners, Cross-tees, Wall Angle or Shadow Moldings of types, structural classifications, and finishes indicated and that comply with applicable ASTM C 635 requirements. Comply with all applicable codes and ordinances.
- D. **Attachment Devices:**
Size for 3 times the design load indicated in ASTM C 635, Table 1, Direct Hung unless otherwise indicated.

2.4 ACCESSORIES

- A. Veneer End Cap with factory-applied blocking
- B. Wood Sleeve for alignment
- C. #20 Biscuits for alignment
- D. Finished end (factory mitered)
- E. Blocked end—beam to beam intersection
- F. **Accessories with Options:** Select one (1) option from the choices for each of the following accessories:
 - a.

2.5 FINISH

- A. Factory Finishing: Panel shall be factory–finished with manufacturer’s standard lacquer products per color selection by architect.
- B. Due to the nature of real wood (variation in grain, texture and color) the finished product may range from light to dark affecting the look of the panels.

PART 3 – EXECUTION

3.1 EXAMINATION

- A. **General:**Examine substrates and structural framing to which ceilings attach or abut, with installer present, for compliance with requirements specified in this and other sections that affect ceiling installation and anchorage. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.2 INSTALLATION AND ADJUSTMENTS

- A. Comply with manufacturer’s instruction and recommendations for installation of wood beams and industry standards
- B. Coordinate the exact size, location, and sequencing of beams
- C. Layout beam pattern per manufacturer’s approved shop drawings if required. Where not otherwise indicated, lay out beam so margins on opposite sides of rooms are equal.
- D. Adjust beams after installation so that surfaces are aligned, flush, and level with gaps between units consistent in width and straight

3.3 CLEANING

- A. **General:** Clean exposed wood surfaces of wood ceiling panels. Comply with manufacturer’s instructions for cleaning and touchup of minor finish damage. Remove and replace wood ceiling components that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage

3.4 INSPECTION

- A. When LINEA Ceiling & Wall Systems ACCENT WOOD BEAMS have been completely installed, the owner and/ or the owner’s representative shall inspect all finished surfaces of the wood ceiling system to validate that the work has been completed in compliance with these specifications. Any defect in meeting installation specifications shall be corrected by the installation contractor at no additional cost to the owner and/or LINEA Ceiling & Wall Systems.

END OF SECTION